

The preliminary results from Prezant's wipe sampling for lead conducted on 5/11/2004, after re-cleaning and re-application of encapsulant in the area that had previously failed clearance in the F.S. 31 basement is as follows:

Floor beneath fixed equipment, East of Tower - Equipment Room <25 ug/sq.ft. (none detected)

Our criteria for lead removal was set at 40 ug/sq.ft. Therefore, the sample listed above passes the criteria.

Since this was the last area that had previously failed at clearance samples, the entire basement has now passed the clearance, and we consider the cleanup of lead contamination successful in achieving levels of lead of below 40 ug/sq.ft.

Katja Jacob
Senior Industrial Hygienist
Prezant Associates, Inc.